



Towards Positive Energy Districts – Innsbruck „Campagne Areal“

Fabian Ochs, Samuel Breuss, Elisa Venturi, Mara Magni, Georgios Dermentzis

ISEC 2024, Graz

New District Campagne Areal

Campagne Areal:

- 4 blocks
 - ca. 1100 flats
 - in 16 buildings
 - ca. 78000 m²
-
- **Residential**
 - Shops and Cafes
 - School and kindergarten
 - Sport facilities



NHT Neue Heimat Tirol




IIG, NHT *expressiv für Bogenfeld Architektur*


New District Campagne Block 1

- 4 buildings
 - 307 flats and non-residential activities
 - 22277 m²
- Space heating demand (PHPP):
15 – 21 kWh/(m² a)
- MVHR
- Central block heating system (2+2 pipes)
 - Central groundwater heat pump (HP)
 - District heating (DH) Innsbruck
- PV on roofs of 3 buildings
(B: 81, C: 80, D: 32; ca. 324 m², ca. 54 kW_p)

Towards Positive Energy District (PED) ...



Central block heating system with DH and HP



2+2 pipe system:

- SH: central groundwater heat pump
 - Heat emission: floor heating
- DHW: district heating (Innsbruck)
 - Fresh water station (FWS) in each apartment

Integration of HP in DH

Motivation

- Decarbonisation of DH
- Source limitation (e.g. limited ground water)
- Restrictions/constraints regarding space or sound emissions (A-HP)


Centralisation

- District Level
- Block Level
- Building Level (individual source, common source)
- Flat Level (e.g. DHW-HP)

Application

- Space Heating (SH)
- Domestic Hot Water (DHW)
- SH + DHW

Share (0 ... 100%)



G Dermentzis, F Ochs, A Thür, W Streicher, Supporting decision-making for heating and distribution systems in a new residential district-An Austrian case study, Energy 224, 120141

F Ochs, M Magni, G Dermentzis, Integration of Heat Pumps in Buildings and District Heating Systems—Evaluation on a Building and Energy System Level. Energies 2022, 15, 3889

Integration of HP in DH

Motivation

- Decarbonisation of DH
- Source limitation (e.g. limited ground water)
- Restrictions/constraints regarding space or sound emissions (A-HP)

Centralisation

- District Level
- Block Level
- Building Level (individual source, common source)
- Flat Level (e.g. DHW-HP)


Application

- Space Heating (SH)
- Domestic Hot Water (DHW)
- SH + DHW

Share (0 ... 100%)


DH / Central HP

Low HP performance
(high sink temperature)




HP for SH, DH for DHW

Flat load curve



HP for DHW, DH for SH

Low load hours, high
peak power



G Dermentzis, F Ochs, A Thür, W Streicher, Supporting decision-making for heating and distribution systems in a new residential district-An Austrian case study, Energy 224, 120141


F Ochs, M Magni, G Dermentzis, Integration of Heat Pumps in Buildings and District Heating Systems—Evaluation on a Building and Energy System Level. Energies 2022, 15, 3889

Analysis of monitoring data comparison with design values

- Thermal comfort
- (IAQ)
- Space heating demand
- Domestic hot water demand
- Storage and Distribution losses
- Tapping profiles, simultaneity
- Heat pump performance




NHT Neue Heimat Tirol




Monitoring system


Monitoring period:
May 2022 - ongoing



Thermal comfort (Building C)




Space heating demand



(*) including part of the distribution losses

Domestic Hot Water (Useful energy) - Building C




	DHW demand [kWh/person/year]
PHPP	529
Monitoring	320

$\Delta = 39\%$


(acc. to PHPP)

Storage and Distribution losses (Building C)



- High setpoint DHW heat exchangers (65°C → 60°C vs. 52°C PHPP)
- High distribution losses ...

Heat pump performance





1) Heat pump




2) Heat pump and well pump

3) Central system

Heat pump performance





Solar Potential



Solar Potential



Areas in [m²] available for PV on roof and facades and share in [%] with respect to total available area

	Roof		Facades	
Total	4798		16430	
Available (ideal case)	2841	59 %	11175	68 %
Available (real case)	2658	55 %	2164	13 %



Solar Potential

Winter gap!



Solar Potential

Net CO₂ Balance

- SH
- DHW
- AUX
- APP

Additionally required (not shaded) horizontal PV area to reach Net Zero CO₂ balance (in [m²] and percentage of football fields)

	(a)		(b)		(c)		(d)	
f _{monthly}	1241	25%	2482	50%	3068	61%	2347	47%
f _{mean}	1031	21%	2184	44%	2614	52%	2060	41%
f _{OIB}	1031	21%	2184	44%	2146	43%	1758	35%

- (a) Heat pump for each building (SH and DHW)
- (b) Heat pump for each building (SH) and direct electric (DE) DHW preparation with E-boilers
- (c) District heating for SH and DHW
- (d) Central heat pump for SH, district heating for DHW (as built)**

F Ochs, G Dermentzis, Evaluation of efficiency and renewable energy measures considering the future energy mix, IBPC 2018

Conclusions and Outlooks

- Very high building quality (Passive House) is prerequisite to reach PED
- Low storage and distribution losses and minimal auxiliaries (careful planning and quality control)
- Appliances included (EV not)
- Real PV potential significantly reduced due to (self) shading
- Winter gap – monthly CO₂ conversion factors
- Future work on detailed evaluation of PED with DH

PED ... more a vision

Acknowledgments

- Project “Monitoring Innsbruck Campagne” is supported by Klima- und Energiefonds (FFG), Leuchttürme für resiliente Städte 2040 - Ausschreibung 2022.



- The outcomes of the Campagne-Areal project will contribute to the international projects:



IEA EBC A83 Positive Energy Districts

Annex 61

IEA HPT A61 Heat Pumps in Positive Energy Districts



IEA SHC T66 Solar Energy Buildings

- The authors are grateful for the collaboration and support:



Thank you!
fabian.ochs@uibk.ac.at

