

Design and Economic Analysis of a Solar Thermal Pre-cooling System for Agro-Produce Cold- Chain in Lesotho

Name: Mpho Yengane

Institution: Energy Research Centre at National University of Lesotho

Co-Authors: M. Mpholo, S. Mokeke

Date: 10.04.24

Presentation Structure

- Problem statement, Research Question & Objectives
- Literature Review & Gaps
- Research Methods
- Findings
- Conclusions, Future Work & Recommendations

Problem statement, Research Question & Objectives

Problem Statement:

- Prelude
 - Agriculture contributes 17% to GDP in Lesotho.
 - Over 70% of Basotho rely on crop production for food & income.
- Lesotho faces 30-40% post-harvest losses
 - Exacerbating 49.7% poverty rate.
- Traditional cold storage is costly, impacting small-scale farmers.
 - Electricity Cost: \$50,000 per 20 m² p/a.
- Solar thermal cooling not implemented due to awareness gaps, lack of research, & financial constraints.



Problem statement, Research Question & Objectives

Research Question:

- What is the feasibility (design, integration, & economic impact) of solar thermal refrigeration in Lesotho's agro-produce cold chain?

Objectives:

- Evaluate potential for solar thermal pre-cooling in agro-produce cold-chain
- Design technically efficient & cost-effective system (Considering Collector efficiency, Coefficient of performance, Solar fraction, Exergy efficiency & Primary energy savings).
 - Achieve 0-12°C pre-cooling for vegetables
- Evaluate economic benefits (Using Levelized cost of energy, Net present value, & Discounted pay-back period).

Literature Review & Gaps:

Gaps


- No Lesotho-specific studies (Also limited studies in SSA).
- Economic viability unclear, especially for farmers.
- Focus is mainly on HVAC.
- Existing Studies lack design & economic analysis (Only Socio-Economic).
- Implementation in Kenya showed better economic performance for B to B model – 30% profit margin

System Design: *Cooling Technology*


Coefficient of performance (COP): Ratio of useful heating or cooling provided to work (energy) required.

*Only COP values from 0.5 – 0.8 used

- Desiccant Cooling (Low COP)
- Adsorption Cooling (Low COP)
- ✓ **Absorption Cooling (High COP)**



TRNSYS Schematic



CoolSelector Sizing

*Gives a visual
representation

of the cold-room*

• Cooling requirement:
7.318 kW

• Target Produce:

- Tomato
- Green beans
- Green pepper
- Cabbage

Cold Room - Step 2 of 5: Review Cold Room Load

The inputs below are necessary to calculate the required cooling capacity of the Cold Room:

Length: 4,00 m	Room conditions:	Goods:
Width: 4,00 m	Temperature: 6,1 °C	Vegetables
Height: 4,00 m	Relative humidity: 95 %	Quantity per day: 3456 kg
<input checked="" type="radio"/> Inner dimensions	Operating hours: 11,7 h	Inlet temperature: 20,0 °C
<input type="radio"/> Outer dimensions		Respiration heat load:
		Total mass in room: 17280 kg

Air exchange (infiltration):

Temperature: 20,0 °C

Relative humidity: 56 %

☒ Door openings:

Regular

☐ Air exchange rate: 6,25
(times room volume per 24 hours)

Heat transfer:

☒ Standard panels ☐ Custom panels

Type: Polyurethane

Thickness: 75,00 mm

Temperature of surroundings: 20,0 °C

Temperature below floor: 12,0 °C

☒ Floor is insulated

Additional loads

Lights: 0 W

Fans: 0 W

People: 2 h/day

Other: 0 W

☐ Defrost

☐ Electric ☒ Natural

Power: 0 W

Defrosts per day: 0

Defrost time: 0 min

Visual Representation:

Navigation: < Prev Next >

Findings: *System Performance (1)*


Collector efficiency (C.E): Ratio of the energy produced in the form of heat by the collector to the total solar energy received by it.

- Highest Collector efficiency at 30°


Exergy efficiency (E.E): Evaluate the effectiveness of the system relative to an idealized or reversible system equivalent

- High COP => High E.E

Collector efficiency vs. collector slope



Exergy efficiency (E.E) vs. rated COP





Findings: *System Performance (2)*

Solar Fraction (S.F): Fraction of energy requirement contributed by solar thermal energy

- Larger Collector Area => High SF
- High COP => High SF

Primary energy savings (P.E.S): Energy saved with reference to traditional source (Electricity)

- Larger Area => High PES
- High COP => High PES





Findings: *Economic Analysis (LCOE)*

Levelized cost of energy (LCOE): Cost of energy associated with the generation of solar energy for cooling

- Lowest LCOE (COP=0.8)
=\$0.085/kWh

Net present value (NPV):
Represents the present value of the system's future discounted cash flows
Highest NPV (COP=0.8)
=\$9,200




Findings: *Economic Analysis (DPP)*

Discounted pay-back period (DPP):

Gives the number of years
it takes to break even

- Payback in 12 yrs (COP=0.8).



Conclusion, Future Work and Recommendations:

Optimal Configuration:

- COP = 0.8, collector area = 12 m², hot storage volume = 0.2 m³.

Financial Feasibility:

- **LCOE:** Achieved \$0.085/kWh .
- **NPV:** \$9,200, Highest.
- **DPP:** Shortest DPP of 12 years.

Financial Viability: Potentially profitable investment for Lesotho cold-chain.

Cost-Effective Operation: Emphasis on lower LCOE & shorter DPP for early break-even.

Recommendations for cost effectiveness

- Scaling Up, Advanced Technologies, Local Manufacturing, Proactive Maintenance, Government Incentives

Future Research Direction

- Advanced Optimization Techniques, Dynamic Models, Thorough Market Analysis, Real-World Implementation

ISEC

3rd INTERNATIONAL
SUSTAINABLE ENERGY
CONFERENCE 2024



THANK YOU

For Further Interest

email: mp hoyengane@gmail.com

