

FEASIBILITY OF HEAT PUMPS SUPPLYING DISTRICT HEATING SYSTEMS


CASE STUDY FOR AUSTRIA AND DENMARK

Wiebke Meesenburg¹, Roman Geyer², Olatz Terreros², Henrik Pieper¹, Torben Ommen¹,
Brian Elmegaard¹



¹ Technical University of Denmark, Department of Mechanical Engineering, Section of
Thermal Energy

² AIT Austrian Institute of Technology GmbH, Integrated Energy Systems Group,

Motivation








Motivation





Boundary conditions

Waldkarte Österreich




Frame conditions for large HPs



Feasibility analysis

- Standard cost-benefit analysis evaluation method
 - Comparison DH solutions and individual heating supply
 - District heating assessment tool
- Levelized cost of energy for local society
- Socioeconomic net present value



<https://ens.dk/en/our-responsibilities/global-cooperation/district-heating-assessment-tool-dhat>



Cases



- Heat sparse areas
- Area 340 000 m²
- New development
 - No existing district heating grid
 - High energy efficiency standard of buildings
- Variable COP of HPs according to source temperature
- Sewage water temperature: 12.5 °C
- Ground water temperature: 10 °C
- Weather compensation below 5 °C outdoor temperature

Land area	Plot ratio	DH temperature	Specific heat demand	Central unit	Individual units
<ul style="list-style-type: none"> • 340 000 m² 	<ul style="list-style-type: none"> • 0.1 • ... • 1.4 	<ul style="list-style-type: none"> • 60 °C / 30 °C • 70 °C / 40 °C • 80 °C / 50 °C 	<ul style="list-style-type: none"> • DHW/SH: • $20 \frac{kWh}{m^2 a} / 3 \frac{kWh}{m^2 a}$ • $20 \frac{kWh}{m^2 a} / 22.5 \frac{kWh}{m^2 a}$ 	<ul style="list-style-type: none"> • Air-source HP • Groundwater HP • Sewage water HP • Wood pellet boiler • Wood chips boiler 	<ul style="list-style-type: none"> • Air-source HP • Ground-source HP • Electric heater



DHW – domestic hot water, SH – space heating, HP – heat pump

Levelized cost of energy

DH temperatures: 60/30 °C, Specific heat demand: minimum space heating



Influence of DH temperatures and fuel prices




- HP Air
- HP Groundwater
- HP Sewage
- Wood chips boiler
- Wood pellet boiler

- HP Air
- HP Groundwater
- HP Sewage
- Wood chips boiler
- Wood pellet boiler

Cost composition


Denmark, DH temperatures: 60 °C/ 30 °C, DHW / SH: $20 \frac{kWh}{m^2 a}$ / $22.5 \frac{kWh}{m^2 a}$

Cost composition



- District heating Pumpin cost
- District heating Fixed O&M
- District heating Investment
- Gas boiler
- Electric boiler
- Air-source HP Fixed O&M
- Air-source HP Investment (incl. VAT and residual value)
- Air-source HP heat production cost

Socioeconomic net present value




- HP Air AUT
- Wood chips boiler AUT
- HP Groundwater AUT
- Wood pellet boiler AUT
- HP Sewage AUT
- HP Air DK
- HP Groundwater DK
- HP Sewage DK
- Wood chips boiler DK
- Wood pellet boiler DK

Conclusion feasibility study

Large-scale heat pumps are feasible supply solutions for heat sparse district heating grids.
The feasibility is influenced by:


Positive

- large linear heat demand densities
- Low DH supply temperature
- Reduction in electricity price (compared to biomass)
- Low space heating shares -> reduced seasonal peaks




Negative

- Reduction in electricity price (compared to individual HPs)
- Reduction in alternative fuel prices
- Subsidies on alternative technologies
- Low space heating shares -> minimum feasible LHDD increases



Conclusion barriers and policy



- Requirement of private- and socioeconomic feasibility benefits large-scale HPs
- Non-profit principle -> no need for short payback time
- Balanced subsidy schemes
- Existing value chains and tradition for alternative technologies might benefit current technologies
- CHP requirement can be a barrier if applied
- Information, collection and dissemination of knowledge!

Thank you for your attention 😊


Wiebke Meeseburg

PhD student

Technical University of Denmark
Mechanical Engineering, Section of thermal energy
Nils Koppels Allé 403, DK-2800 Kgs.Lyngby
wmeese@mek.dtu.dk
Tel.: 0045 45254118
www.dtu.dk



Socioeconomic net present value (NPV)




$$NPV_{project} = NPV_{DH} - NPV_{individual}$$

Includes societal costs

- No taxes
- Emission costs

Levelized cost of energy (LCOE)



$$LCOE = \frac{NPV_{DH}^{localsociety}}{\sum_{i=1}^N (Q_{tot,i})}$$

N – project life time

$Q_{tot,i}$ – yearly heat supply

$NPV_{DH}^{localsociety}$ – local society NPV of the DH solution

The levelized cost of energy (LCOE) methodology discounts all projected expenditures and revenues to their net present value in a specific year – equivalent to the average expected price for consumers in order to repay all costs. The methodology is useful from a societal perspective comparing alternative heat generation technologies.


Cost functions

Table 2 Investment cost and lifetime for central and decentral units

Technology	Investment [M€/MW] linear/power function		Lifetime [a]	Sources
HP Groundwater	$1.1117 \dot{Q}_{nom}^{-0.23105}$	$1.236 \dot{Q}_{nom}^{-0.2599}$	25	[31]
HP Sewage water	$1.2166 \dot{Q}_{nom}^{-0.33122}$	$1.1038 \dot{Q}_{nom}^{-0.2435}$	25	[31]
HP Air	$0.9366 \dot{Q}_{nom}^{-0.1418}$	$1.0503 \dot{Q}_{nom}^{-0.3078}$	25	[31]
Wood chips boiler		0.9	20	[32]
Wood pellet boiler		0.48	20	[32]
Electric boiler		0.11	20	[32]
Gas boiler		0.06	25	[32]
Indv. Air to water HP		0.95	15	[32]
Indv. Brine to water HP		1.52	20	[32]
Indv. Electric heater		0.86	30	[32]

- [31] H. Pieper, T. Ommen, F. Bühler, and B. Lava, "Allocation of investment costs for large-scale heat pumps supplying district heating Contact information :," vol. 00, p. 64014, 2017.
- [32] Energinet.dk, "Technology Data for Energy Plants," 2016. [Online]. Available: www.ens.dk. [Accessed: 12-Oct-2017].

Boundary conditions




Sources:

Danish Energy Agency, *Energy statistics 2016*. Danish Energy Agency, 2018.


Energie-Control Austria, "Key Statistics 2016," 2016.

Bundesministerium für Wissenschaft, Forschung und Wirtschaft, "Energie in Österreich - Zahlen, Daten, Fakten," 2017.

Case study



- Heat sparse areas
- Area 340 000 m²
- New development
 - No existing district heating grid
 - High energy efficiency standard of buildings



- Variable COP of HPs according to source temperature
- Sewage water temperature: 12.5 °C
- Ground water temperature: 10 °C
- Weather compensation below 5 °C outdoor temperature

